



Legend

- APPLICATION SITE BOUNDARY
- EXISTING PENTIR SUBSTATION
- PROPOSED UNDERGROUND CABLE ROUTES

NOTES:

- EQUIPMENT FOUNDATIONS & SUPPORTS SHOWN ARE INDICATIVE
- EQUIPMENT RATINGS ARE TO BE CONFIRMED WHEN THE SIGNED SDS IS RECEIVED FROM NATIONAL GRID
- EXISTING CVT WITH SUPPORT STRUCTURE WILL BE RELOCATED FROM THE PRESENT LOCATION TO THE OTHER SIDE OF THE CIRCUIT IN ORDER TO ACCOMMODATE ADDITIONAL SET OF CSE
- ALL PROPOSED UNDERGROUND WORKS ARE WITHIN THE EXISTING PENTIR OPERATIONAL SUBSTATION BOUNDARY

Notes

This drawing is scaled at paper size A0, therefore any prints taken at smaller sizes will affect accuracy of the measurement units and should not be scaled against

Scale Bar

10m 5m 0m 25m 50m
1:500

BACKGROUND MAPPING INFORMATION HAS BEEN REPRODUCED FROM THE ORDNANCE SURVEY BY PERMISSION OF ORDNANCE SURVEY OF THE CONTROLLER OF HER MAJESTY'S STATIONARY OFFICE CROWN. © COPYRIGHT AND DATABASE RIGHTS 2024 ORDNANCE SURVEY 0100031673.

P01	12/09/25	FIRST ISSUE	TM	MT	RW
Issue	Date	Remarks	Drawn	Checked	Approved

Title

PENTIR
PROPOSED UNDER GROUND WORKS
(FOR TCPA)

nationalgrid

Figure Number

PTC1 / PTNO - PENTIR

Drawing Reference

PTNO-WSP-SS52-C00484-DRW-CP-000003

Scale 1:500	Sheet Size A0	Sheet SHEET 1 OF 1	Issue 1
---------------------------	-----------------------------	----------------------------------	-----------------------