




Setting Out table			
Setting Out Point Number	Easting	Northing	Proposed Ground Level (mAOD)
1	259367.925	338667.476	4.200
2	259340.006	338723.888	4.200
3	259396.469	338751.832	4.200
4	259410.613	338723.254	4.200
5	259433.575	338715.403	4.200
6	259443.212	338695.930	4.200
7	259437.724	338679.686	4.200
8	259408.671	338665.326	4.200
9	259399.799	338683.251	4.200
10	259402.761	338692.016	4.200
11	259436.809	338708.868	4.200
12	259383.115	338697.655	4.200
13	259376.979	338710.052	4.200

Key Plan

Notes

- Do not scale from this drawing.
- Drawing to be printed in colour.
- All dimensions in millimetres unless otherwise stated.
- CSE Compound main earthing (MES) and fence earthing will maintain a 2m separation distance in line with NGTS 3.01.02 Section 1.1.1.3.
- For detailed landscaping refer to AECOM Landscaping Plan.
- All palisade fencing shall be in accordance with BS 1722-12:2016, type reference GP24. The overall height of the fence shall be 2.4m above base level (Category 2 fencing system in accordance with NG TS2.10.02).
- An electric pulse fence is to be installed to the back of the Category 2 palisade fence and gates as part of the standard fence construction. The electric fence shall extend from ground level to 1.0m above the top of the fence pales.

Cable Sealing End Compound Equipment Key

Work site boundary

New Equipment to be added

Legend

Marshy Grassland

Scrub Planting

Neutral Grassland

Woodland Edge

Ditch Grassland Fieldlayer

Planted Tree

Proposed underground cable route (Only shown for context)

Access Road

Minfordd CSE Compound (crushed rock surfacing)

Pond

EVIP Headhouse Garth Compound (reinforced grass surfacing)

Proposed Low Voltage Pit

Proposed Comms Pit

Proposed CSEC Perimeter Fence

Proposed Pond Perimeter Post & Rail Fencing

Proposed Pond Perimeter Gate

Proposed Ø450mm inspection chamber

Proposed Drain Headwall Outfall

Proposed Ø1200mm Manhole

Proposed Ø1350mm Flow Control Manhole

© Crown copyright and database rights 2023 Ordnance Survey 0100031673

This document is issued for the party which commissioned it and for specific purposes connected with the captioned project only. It should not be relied upon by any other party or used for any other purpose. We accept no responsibility for the consequences of this document being relied upon by any other party, or being used for any other purpose, or containing any error or omission which is due to an error or omission in data supplied to us by other parties.

MURPHY

WORLD-CLASS INFRASTRUCTURE

nationalgrid

National Grid

ARUP

8 Fitzroy Street London W1T 4BJ, United Kingdom
Tel +44(0)20 7636 1531 Fax +44(0)20 7580 3924
www.arup.com

C	12/09/25	RA	RB	GT	Updated following NG comments
B	07/08/25	BA	RB	GT	Updated following NG comments
A	11/06/25	BA	GT	GT	Issued for Planning
ISSUE	DATE	DRAWN	CHECKED	APPROVED	REMARKS

Draft WIP

Dwg Title:
Planning Drawings
Minfordd CSE Compound
Proposed Site Plan

Site: Glaslyn Cable Uprating

A1
100%

CAD

Originator
Dwg No: GLAS-ARUP-71-XX-DR-X-9240

Originators
Proj.Ref: 295280-00

NG Investment
No:



Sheet No: 1


Total No. of Sheets: 2

Issue: C

NG
Dwg No:


Scale: 1:250





©CROWN COPYRIGHT. UNAUTHORISED REPRODUCTION INFRINGES CROWN COPYRIGHT AND MAY LEAD TO PROSECUTION OR CIVIL PROCEEDINGS
LICENCE NUMBER: 100024241


- NOTE:
1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS, DOCUMENTS AND SPECIFICATIONS.
 2. DO NOT SCALE FROM THIS DRAWING. USE ONLY DIMENSIONS PROVIDED.
 3. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
 4. EXTERNAL RWP'S TO BE INSTALLED (DETAILED TO BE VISUALLY UNINTRUSIVE AND NOT EASILY CLIMBED)



P03	AMENDED FOR CHANGES	XX	XX	XX	08.09.25
P02	ISSUED FOR PLANNING	MAC	CN	CN	31.10.19
P01	ISSUED FOR TENDER	JR	GG	CM	12.07.19
Rev	Description	Cre'd	Chk'd	App'd	Date

nationalgrid

Master Scheme No: 33494	Sub-Scheme No: VIP	Site: SNOWDONIA WEST SITE
Scheme Name: WEST HEAD HOUSE		
Document Title: EAST AND WEST ELEVATIONS GARTH		
Created by: JR	Date: 07.06.19	Checked by: GG
Development Eng:	Document Type: ARC	Scale: 1:100
Date: 07.06.19	Format: A1	Approved by: CM
Sheet(s): 1 OF 1	Revi: P03	Date: 07.06.19
National Grid Document Number: PDD-33494-ARC-220		
FEED Document Number: *****		



©CROWN COPYRIGHT. UNAUTHORISED REPRODUCTION INFRINGES CROWN COPYRIGHT AND MAY LEAD TO PROSECUTION OR CIVIL PROCEEDINGS
LICENCE NUMBER: 100024241

NOTE:

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS, DOCUMENTS AND SPECIFICATIONS.
2. DO NOT SCALE FROM THIS DRAWING. USE ONLY DIMENSIONS PROVIDED.
3. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
4. EXTERNAL RWP'S TO BE INSTALLED (DETAILED TO BE VISUALLY UNINTRUSIVE AND NOT EASILY CLIMBED)

Rev	Description	Cre'd	Chk'd	App'd	Date	
P03	AMENDED FOR CHANGES		XX	XX	XX	08.09.25
P02	ISSUED FOR PLANNING		MAC	CN	CN	31.10.19
P01	ISSUED FOR TENDER					12.07.19

nationalgrid

Master Scheme No: 33494	Sub-Scheme No: VIP	Site: SNOWDONIA WEST SITE			
Scheme Name: WEST HEAD HOUSE					
Document Title: NORTH AND SOUTH ELEVATIONS GARTH					
Created by: JR	Date: 04.06.19	Checked by:	Date:	Approved by:	Date:
Development Eng:	Document Type: ARC	Scale: 1:100	Format: A1	Sheet(s): 1 OF 1	Rev: P03
National Grid Document Number: PDD-33494-ARC-221					
FEED Document Number: *****					