

HVDC Network Code – Update

Code Drafter: Darren Chan
Sept 2013 JESG

Current Progress

- 1st Draft for public consultation is being finalised (Sept – Oct)
- Outcome from 2nd User Group meeting (11 June)
 - Focus on onshore AC side requirements
 - Be cognisant of inherent technical capabilities
 - Alignment with RfG/DCC as far as possible
 - Agreement on Significant Grid Users
 - Technology neutrality should not be a barrier to development
- Some Initial Comments from 3rd User Group Meeting (12 Sept)
 - Important to get clear definitions
 - Conflicting requirements from both ends of “Relevant TSOs”
 - Reactive requirements – too much offshore; should be local issue
 - Some requirements are unnecessary and add to upfront costs
 - Unbalance Information exchange – too little from TSOs
 - Need an offshore code


HVDC Code Key Dates

- 29 April 2013 - Mandate received by ENTSO-E to draft code
- 7 May – 7 June – feedback requested from stakeholders on [Preliminary Scope](#) document and on the questions raised in the [Call for Stakeholder Input](#) document.
- 11 June – 2nd user group meeting
- 12 Sept - 3rd User Group Meeting

Going forwards:

- Publication of Draft Code in early November 2013
- Public consultation 7 Nov 2013 – 7 Jan 2014
- **GB: 2 day stakeholder workshop to step through code and determine key issues**
- 2nd Public workshop end Nov 2013 (TBC)
- 4th User Group meeting Jan 2014
- 5th User Group meeting Feb/Mar 2014
- 3rd Public workshop workshop early April 2014
- 1 May 2014 - Submission of code to ACER
- **GB: May/June 2014 DECC/Ofgem stakeholder workshop to pass on to DECC key issues for comitology**

Significant Grid Users



Requirements for HVDC and PPM

- At HVDC substation(s) at onshore AC end
 - Active power control and frequency support
 - Reactive power control and voltage support
 - Fault ride through
 - Control
 - Protection devices and settings
 - Power system restoration
- Requirements for PPM and HVDC substation
 - PPM – align with RfG if possible
- Information Exchange and Coordination
- Operational Notification Procedure
- Compliance
- Derogations

Power Park Module Requirements


- As far as possible, align with RfG
- The HVDC substation at the PPM end shall meet the same requirements as the PPM if applicable
- Additionally, the HVDC substation at the PPM end shall also meet the requirements of the HVDC substation at the onshore end if applicable
- The PPM and HVDC connection need to be economically coordinated so as not to impair requirements at the onshore AC transmission connection point

Impact on GB - system extension offshore

- Single to multi-terminal
 - If different vendors, control systems have to be compatible
- Initial AC connection of PPM, later addition of DC connection from PPM to a different onshore connection point, or vice versa
 - Is PPM subject to both RfG and HVDC codes?
- Multiple windfarms that are AC connected, extended to form a DC mesh, with DC connections to one or more synchronous areas
 - Does this form a separate offshore synchronous area?

DC Connected PPMs

HVDC connections may become DC connected to another synchronous electricity system



Power Park Module(s) AC collected and DC connected to the main electricity system

Other 3rd party Power Park Module(s) AC collected

AC connection in parallel with HVDC connection to AC collected PPMs

HVDC connections between AC collected PPMs and the main electricity system

— Connection Point(s)

Impact on GB – Compliance and derogation

- Compliance issues
 - Does ownership matter?
 - TSO (i.e, NGET, SPTL, etc)
 - OFTOs
 - Third parties (i.e Britned etc)
- Embedded HVDC systems(i.e within AC system)
 - Single TSO owned, in one control area
 - Multi-TSO owned, in one control area
 - Do these have x-border impact?
- Technical compliance not an issue for Relevant TSOs – necessary for the efficient and secure operation of the transmission system
 - Do TSOs compliance test themselves?

Impact on GB – technical requirements

- OFTOs and PPMs
 - Coordination necessary between PPMs and OFTOs
 - Complexity increases with multi-vendor extensions of system
- Interconnectors
 - Technical requirements – not a major issue
 - Market operation, reserve capacity and firmness are major concerns – not within the scope of this code
- Relevant TSOs - Technical compliance not an issue for TSOs – necessary for the efficient and secure operation of the transmission system
 - Do TSOs have to subject themselves to their own compliance procedure?
- Retrospective Application
 - CBA required for existing systems
 - Likely to dictate limited scope of retrospective application, with only minor software/control system changes being viable