Date	14/02 AM	14/02 PM	15/02 AM	15/02 PM	16/02 AM	16/02 PM	17/02 AM	17/02 PM	18/02 AM	18/02 PM	19/02 AM	19/02 PM	20/02 AM	20/02 PM	21/02 AM	21/02 PM	22/02 AM	22/02 PM	23/02 AM	23/02 PM	24/02 AM	24/02 PM	25/02 AM	25/02 PM
MW away from risk of System Level NRAPM (Forecast Conditions)	0	0	0	0	0	0	0	0	0	0	0	0	0	0										
MW away from risk of Scotland Level NRAPM (Forecast Conditions)	0	0	0	0	0	0	0	0	0	0	0	0	0	0										

Week Number	08W18	09W18	10W18	11W18	12W18	13W18	14W18	15W18	16W18	17W18	18W18	19W18	20W18	21W18	22W18	23W18	24W18	25W18	26W18	27W18	28W18	29W18	30W18	31W18	32W18	33W18	34W18	35W18	36W18	37W18	38W18	39W18	40W18	41W18	42W18	43W18	44W18	45W18	46W18	47W18	48W18	49W18	50W18	51W18	52W18	01W19	02W19	03W19	04W19	05W19	06W19
Date	25/02/2018	04/03/2018	11/03/2018	18/03/2018	25/03/2018	01/04/2018	08/04/2018	15/04/2018	22/04/2018	29/04/2018	06/05/2018	13/05/2018	20/05/2018	27/05/2018	03/06/2018	10/06/2018	17/06/2018	24/06/2018	01/07/2018	08/07/2018	15/07/2018	22/07/2018	29/07/2018	05/08/2018	12/08/2018	19/08/2018	26/08/2018	02/09/2018	09/09/2018	16/09/2018	23/09/2018	30/09/2018	07/10/2018	14/10/2018	21/10/2018	28/10/2018	04/11/2018	11/11/2018	18/11/2018	25/11/2018	02/12/2018	09/12/2018	16/12/2018	23/12/2018	30/12/2018	06/01/2019	13/01/2019	20/01/2019	27/01/2019	03/02/2019	10/02/2019
Wind Load Factor required to cause a System Level NRAPM	1.65	1.90	1.88	1.47	1.39	1.13	1.17	1.25	1.17	0.96	0.93	0.95	1.1	0.56	0.53	0.61	0.57	0.55	0.68	0.61	0.43	0.57	0.52	0.45	0.57	0.56	0.55	0.62	0.57	0.61	0.66	0.56	0.61	0.51	0.51	1.14	0.93	1.13	1.14	1.36	1.43	1.42	1.54	1.31	0.91	1.17	1.71	1.57	1.36	1.31	1.77
Probability of seeing Wind load factor above	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	7%	3%	0%	2%	1%	1%	2%	1%	0%	3%	58%	4%	2%	4%	7%	1%	0%	0%	0%	2%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Wind Load Factor required to cause a Scotland Level NRAPM	1.71	1.96	1.70	1.64	1.19	1.58	1.62	1.64	1.50	1.35	1.34	1.44	1.44	1.26	1.27	1.35	1.27	1.25	1.39	1.26	1.14	1.30	1.29	1.19	1.41	1.34	1.38	1.42	1.36	1.53	1.53	1.54	1.54	1.65	1.64	1.82	1.61	1.68	1.67	1.75	1.65	1.61	1.66	1.58	1.43	1.52	1.73	1.57	1.61	1.61	1.73
Probability of seeing Wind load factor above	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

The forecast is meant as a guide and does not take into account action on pump storage or Interconnectors which will be done as required in control room timescales.

The RAG for the 7-14 National level is based on a surplus higher than 1000MW for green, between 500 and 1000MW for amber and less than 500MW for Red it includes a MW level away from the risk

The RAG for the 2-14 Scottish level is based on a surplus higher than 400MW for green, between 0 and 400MW for amber and below 0MW for Red it includes a MW level away from the risk.

The weekly 2-52 RAG is the load factor of wind required to cause an NRAPM and then the % probability of getting this load factor. So the percentage can be read as the probability of an NRAPM for each week in with yellow for between 5% and 20% and Red for over 20%.