Date	14/02 AM	14/02 PM	15/02 AM	15/02 PM	16/02 AM	16/02 PM	17/02 AM	17/02 PM	18/02 AM	18/02 PM	19/02 AM	19/02 PM	20/02 AM	20/02 PM	21/02 AM	21/02 PM	22/02 AM	22/02 PM	23/02 AM	23/02 PM	24/02 AM	24/02 PM	25/02 AM	25/02 PM	26/02 AM	26/02 PM
MW away from risk of System Level NRAPM (Forecast Conditions)	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]										
MW away from risk of Scotland Level NRAPM (Forecast Conditions)	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]										

Week Number	08/W18	09/W18	10/W18	11/W18	12/W18	13/W18	14/W18	15/W18	16/W18	17/W18	18/W18	19/W18	20/W18	21/W18	22/W18	23/W18	24/W18	25/W18	26/W18	27/W18	28/W18	29/W18	30/W18	31/W18	32/W18	33/W18	34/W18	35/W18	36/W18	37/W18	38/W18	39/W18	40/W18	41/W18	42/W18	43/W18	44/W18	45/W18	46/W18	47/W18	48/W18	49/W18	50/W18	51/W18	52/W18	01/W19	02/W19	03/W19	04/W19	05/W19	06/W19
Date	25/02/2018	04/03/2018	11/03/2018	18/03/2018	25/03/2018	01/04/2018	08/04/2018	15/04/2018	22/04/2018	29/04/2018	06/05/2018	13/05/2018	20/05/2018	27/05/2018	03/06/2018	10/06/2018	17/06/2018	24/06/2018	01/07/2018	08/07/2018	15/07/2018	22/07/2018	29/07/2018	05/08/2018	12/08/2018	19/08/2018	26/08/2018	02/09/2018	09/09/2018	16/09/2018	23/09/2018	30/09/2018	07/10/2018	14/10/2018	21/10/2018	28/10/2018	04/11/2018	11/11/2018	18/11/2018	25/11/2018	02/12/2018	09/12/2018	16/12/2018	23/12/2018	30/12/2018	06/01/2019	13/01/2019	20/01/2019	27/01/2019	03/02/2019	10/02/2019
Wind Load Factor required to cause a System Level NRAPM	1.65	1.92	1.88	1.47	1.39	1.13	1.17	1.25	1.17	0.96	0.93	0.93	1.1	0.56	0.53	0.61	0.57	0.55	0.68	0.61	0.47	0.57	0.52	0.45	0.57	0.64	0.65	0.62	0.57	0.61	0.96	0.93	0.91	0.91	1.11	1.14	0.93	1.13	1.14	1.36	1.43	1.42	1.54	1.31	0.91	1.17	1.21	1.37	1.34	1.31	1.34
Probability of seeing Wind load factor above	0%	0%	0%	0%	0%	0%	0%	0%	3%	0%	0%	0%	0%	7%	3%	0%	0%	1%	1%	1%	1%	0%	3%	58%	4%	0%	4%	7%	1%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
Wind Load Factor required to cause a Scotland Level NRAPM	1.71	1.96	1.70	1.64	1.19	1.58	1.62	1.64	1.50	1.35	1.39	1.44	1.44	1.26	1.27	1.35	1.27	1.25	1.39	1.26	1.14	1.30	1.29	1.19	1.41	1.34	1.38	1.42	1.36	1.53	1.53	1.54	1.54	1.65	1.64	1.62	1.61	1.68	1.67	1.75	1.65	1.61	1.66	1.58	1.42	1.52	1.51	1.61	1.61	1.51	1.61
Probability of seeing Wind load factor above	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

The forecast is meant as a guide and does not take into account action on pump storage or Interconnectors which will be done as required in control room timescales.

The RAG for the 7-14 National level is based on a surplus higher than 1000MW for green, between 500 and 1000MW for amber and less than 500MW for Red it includes a MW level away from the risk

The RAG for the 2-14 Scottish level is based on a surplus higher than 400MW for green, between 0 and 400MW for amber and below 0MW for Red it includes a MW level away from the risk.

The weekly 2-52 RAG is the load factor of wind required to cause an NRAPM and then the % probability of getting this load factor. So the percentage can be read as the probability of an NRAPM for each week in with yellow for between 5% and 20% and Red for over 20%.